

## FORM – A

[(See Section 3(3) and rule 4(1)  
Certificate by the Licensed Agency regarding the compliance  
of the Fire and Life Safety Measures

## CERTIFICATE

**Ref: NWMC/FIRE/161/24 Dated: 24-07-2024.**

Certified that we have executed the works towards  
Compliance in Relation to Fire prevention and Life Safety measures to be provided  
and Performed other related activities required to be carried out in the  
Following building or premises, as require under the provisions of the  
Maharashtra Fire prevention and Safety measures Act, 2006 (Mah. III of 2007)

Description and Location of Building or Premises

**Govt. Ayurvedic College & Hospital, Wajirabad, Nanded.**

The details of the works and related activities which we have executed or  
performed are mentioned in the list appended herewith

Place: Chha. Sambhajinagar,  
Dated: - 29/05/2025

License No. MFS/LA/2021/RF-111  
License No. MFS/LA/2021/RD-107

For,

**Nagosing** Digitally signed by  
Nagosing  
**Alamsing** Alamsing Chandel  
Date: 2025.05.29  
**Chandel** 09:54:38 +05'30'

M/S. Sai Firetech Engineering Services.

**List of Fire Equipment's and Systems Install Govt. Ayurvedic College & Hospital, Wajirabad, Nanded.**

Measures Act, 2006. We are applicant shall comply with all the fire and life Safety measures adhering to National Building code of India

**INSTALLED ITEMS & QTY.**

**COURT YARD HYDRANT SYSTEM.**

Sr.	Particular	Spec.	Qty.	Unit.
01	Hydrant Main Fire Pump (Ele. Driven)	2280 LPM X 56 H.	02	No.
02	Jockey Pump	180 LPM X 70 H.	01	No.
03	Single Headed Yard Hydrant Valve		14	Nos.
04	Double Door Hose Boxes with RRL & Branch Pipes.		14	Sets.
05	Fire Brigade Inlet Connections	4 Way	02	Nos.

**IPD/OPD BUILDING**

Sr.	Particular	Spec.	Qty.	Unit.
01	Store Pressure type Fire Extinguishers	Co2-4.5 Kg.	10	Nos.
02	Store Pressure type Fire Extinguishers	ABC-06 Kg.	30	Nos.
03	Single Headed Yard Hydrant Valve		06	Nos.
04	Double Door Hose Boxes with RRL & Branch Pipes.		06	Set.
05	Hose Reel Drums complete set.		10	Set.
06	Fire Alarm Control Panel 12 Zone	Conventional	01	Nos.
07	Smoke Detectors	Conventional	150	Nos.
08	Manual Call Points	Conventional	12	Nos.

09	Hooters	Conventional	12	Nos.
10	Fire buckets with stand.	04 Nos/Stand.	01	Set.

**COLLEGE BUILDING**

Sr.	Particular	Spec.	Qty.	Unit.
01	Store Pressure type Fire Extinguishers	Co2-4.5 Kg.	09	Nos.
02	Store Pressure type Fire Extinguishers	ABC-06 Kg.	18	Nos.
03	Single Headed Yard Hydrant Valve		09	Nos.
04	Double Door Hose Boxes with RRL & Branch Pipes.		09	Set.
05	Hose Reel Drums complete set.		09	Set.
06	Fire Alarm Control Panel 08 Zone	Conventional	01	Nos.
07	Smoke Detectors	Conventional	130	Nos.
08	Manual Call Points	Conventional	09	Nos.
09	Hooters	Conventional	09	Nos.
10	Fire buckets with stand.	04 Nos/Stand.	01	Set.

**LIBRARY BUILDING**

Sr.	Particular	Spec.	Qty.	Unit.
01	Store Pressure type Fire Extinguishers	Co2-4.5 Kg.	03	Nos.
02	Store Pressure type Fire Extinguishers	ABC-06 Kg.	05	Nos.
03	Single Headed Yard Hydrant Valve		01	Nos.
04	Double Door Hose Boxes with RRL & Branch Pipes.		01	Set.

05	Hose Reel Drums complete set.		02	Set.
06	Fire Alarm Control Panel 2 Zone	Conventional	01	Nos.
07	Smoke Detectors	Conventional	32	Nos.
08	Manual Call Points	Conventional	04	Nos.
09	Hooters	Conventional	04	Nos.
10	Fire buckets with stand.	04 Nos/Stand.	01	Set.

**PANCHKARMA BUILDING**

Sr.	Particular	Spec.	Qty.	Unit.
01	Store Pressure type Fire Extinguishers	Co2-4.5 Kg.	02	Nos.
02	Store Pressure type Fire Extinguishers	ABC-06 Kg.	04	Nos.
03	Single Headed Yard Hydrant Valve		01	Nos.
04	Double Door Hose Boxes with RRL & Branch Pipes.		01	Set.
05	Hose Reel Drums complete set.		01	Set.
06	Fire Alarm Control Panel 2 Zone	Conventional	01	Nos.
07	Smoke Detectors	Conventional	15	Nos.
08	Manual Call Points	Conventional	01	Nos.
09	Hooters	Conventional	01	Nos.
10	Fire buckets with stand.	04 Nos/Stand.	01	Set.

**PHARMACY BUILDING**

Sr.	Particular	Spec.	Qty.	Unit.
01	Store Pressure type Fire Extinguishers	Co2-4.5 Kg.	09	Nos.
02	Store Pressure type Fire Extinguishers	ABC-06 Kg.	15	Nos.
03	Single Headed Yard Hydrant Valve		03	Nos.
04	Double Door Hose Boxes with RRL & Branch Pipes.		03	Set.
05	Hose Reel Drums complete set.		06	Set.
06	Fire Alarm Control Panel 4 Zone	Conventional	01	Nos.
07	Smoke Detectors	Conventional	70	Nos.
08	Manual Call Points	Conventional	06	Nos.
09	Hooters	Conventional	06	Nos.
10	Fire buckets with stand.	04 Nos/Stand.	01	Set.

### **BOY'S & GIRL'S P. G. HOSTEL BUILDING.**

Sr.	Particular	Spec.	Qty.	Unit.
01	Store Pressure type Fire Extinguishers	Co2-4.5 Kg.	03	Nos.
02	Store Pressure type Fire Extinguishers	ABC-06 Kg.	08	Nos.
03	Single Headed Yard Hydrant Valve		01	Nos.
04	Double Door Hose Boxes with RRL & Branch Pipes.		01	Set.
05	Hose Reel Drums complete set.		02	Set.
06	Fire Alarm Control Panel 8 Zone	Conventional	01	Nos.
07	Smoke Detectors	Conventional	130	Nos.
08	Manual Call Points	Conventional	08	Nos.
09	Hooters	Conventional	08	Nos.

10	Fire buckets with stand.	04 Nos/Stand.	01	Set.
----	--------------------------	---------------	----	------

**GIRL'S UG HOSTEL BUILDING**

Sr.	Particular	Spec.	Qty.	Unit.
01	Store Pressure type Fire Extinguishers	Co2-4.5 Kg.	03	Nos.
02	Store Pressure type Fire Extinguishers	ABC-06 Kg.	08	Nos.
03	Single Headed Yard Hydrant Valve		01	Nos.
04	Double Door Hose Boxes with RRL & Branch Pipes.		01	Set.
05	Hose Reel Drums complete set.		02	Set.
06	Fire Alarm Control Panel 2 Zone	Conventional	01	Nos.
07	Smoke Detectors	Conventional	32	Nos.
08	Manual Call Points	Conventional	06	Nos.
09	Hooters	Conventional	06	Nos.
10	Fire buckets with stand.	04 Nos/Stand.	01	Set.

**BOY'S UG HOSTEL BUILDING**

Sr.	Particular	Spec.	Qty.	Unit.
01	Store Pressure type Fire Extinguishers	Co2-4.5 Kg.	04	Nos.
02	Store Pressure type Fire Extinguishers	ABC-06 Kg.	10	Nos.
03	Single Headed Yard Hydrant Valve		01	Nos.
04	Double Door Hose Boxes with RRL & Branch Pipes.		01	Set.
05	Hose Reel Drums complete set.		02	Set.

06	Fire Alarm Control Panel 2 Zone	Conventional	01	Nos.
07	Smoke Detectors	Conventional	34	Nos.
08	Manual Call Points	Conventional	04	Nos.
09	Hooters	Conventional	04	Nos.
10	Fire buckets with stand.	04 Nos/Stand.	01	Set.

For,

**Nagosing  
Alamsing  
Chandel**

Digitally signed  
by Nagosing  
Alamsing  
Chandel  
Date: 2025.05.29  
09:55:14 +05'30'

M/S. Sai Firetech Engineering Services.



66.1281

270.0000

236.3801

178.37

**LEGEND FOR FIRE HYDRANT SYSTEM**

Symbol	Description	Size	Qty.
	Fire Hydrant Line	150NB	870 MTR
	Fire Hydrant Line	100NB	550 MTR
	Fire Hydrant Line	80 Nos	100 MTR
	Fire Hydrant Line Under Ground	150NB	36 MTR
	Fire Hydrant Line Under Ground	100NB	50MTR
	Hydrant Valve		46 Nos
	Hose Reel Box		46 Nos
	Hose Reel Drum		33 Nos
	Four Way Fire Brigade Inlet		02 No

**LEGEND FOR FIRE HYDRANT PUMP HOUSE**

Symbol	Description	Size	Qty.
	Fire Pump Panel		01
	Diesel Engine Driven Pump For Fire Fighting System	1600 LPM	01
	Electrical Driven Pump for Fire Fighting System	1600 LPM	01
	Jockey Pump For Fire Fighting System	180 LPM	01

DRAWING NAME :  
FIRE HYDRANT SYSTEM LAYOUT

PROJECT :  
AYURVEDIC COLLEGE, KALAMANDIR, NANDED

FIRE CONTRACTOR :  
**Sai Firetech Engineering Services**  
Corporate Office: Plot No. 78, GUT No. 100, Naik Nagar, Opp. Hotel Spice Tree, Beed By-pass, Aurangabad 431010. Tel : 0240-2653393  
Branch Office: 304, Arya Residency - I, Mauza - Nara, Arya Nagar Layout, Koradi Road, Nagpur - 440030